

Map ID  
Direction  
Distance  
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number  
EPA ID Number

**BW373**  
**ESE**  
**1/2-1**  
**0.611 mi.**  
**3226 ft.**

**VAULT VS6224**  
**OCEAN PARKWAY/BRIGHTON AV**  
**BROOKLYN, NY**

**NY Spills** **S104788383**  
**N/A**

**Site 3 of 4 in cluster BW**

**Relative:**  
**Higher**

**SPILLS:**

**Actual:**  
**8 ft.**

Name: VAULT VS6224  
Address: OCEAN PARKWAY/BRIGHTON AV  
City,State,Zip: BROOKLYN, NY  
Spill Number/Closed Date: 0005755 / 2002-02-13  
Facility ID: 0005755  
Facility Type: ER  
DER Facility ID: 69461  
Site ID: 73836  
DEC Region: 2  
Spill Cause: Equipment Failure  
Spill Class: C4  
SWIS: 2401  
Spill Date: 2000-08-13  
Investigator: JHOCONNE  
Referred To: Not reported  
Reported to Dept: 2000-08-13  
CID: 397  
Water Affected: Not reported  
Spill Source: Commercial/Industrial  
Spill Notifier: Responsible Party  
Cleanup Ceased: Not reported  
Cleanup Meets Std: False  
Last Inspection: Not reported  
Recommended Penalty: False  
UST Trust: False  
Remediation Phase: 0  
Date Entered In Computer: 2000-08-13  
Spill Record Last Update: 2002-02-13  
Spiller Name: Not reported  
Spiller Company: CON ED  
Spiller Address: Not reported  
Spiller Company: 999  
Contact Name: CALLER  
DEC Memo: "Prior to Sept, 2004 data translation this spill Lead\_DEC Field was O'CONNELL "  
Remarks: "transformer leaked spilling fluid 20 gallons on top of 500 gallons of water clean up pending results historic record of 10 ppm of pcb"

**All Materials:**

Site ID: 73836  
Operable Unit ID: 826758  
Operable Unit: 01  
Material ID: 546903  
Material Code: 0541A  
Material Name: dielectric fluid  
Case No.: Not reported  
Material FA: Petroleum  
Quantity: 20.00  
Units: G  
Recovered: .00  
Oxygenate: Not reported